

FIRE EXTINGUISHERS - Saturn Class K Wet Chemical - Portable Handheld

Class K extinguishers are extremely effective in suppressing high temperature fires involving cooking oils and grease. The unique cooling properties deliver exceptional heat absorption ensuring the fire remains out.



CLASS K FIRES

Cooking Oils, Greases, and Fats

SPECIFICATIONS:

These units are ideal for commercial restaurant applications as a portable supplement to pre-engineered suppression systems. A low "pH" potassium acetate solution is discharged in a fine mist that provides excellent range while preventing splashing and creating an effective saponification foam-type blanket necessary for suppressing liquid cooking media fires.


Conforms to Test Standards: CAN/ULC-S554-ANSI/UL8 & CAN/ULC-S508-ANSI/UL711

Operation: Squeeze the lever, which opens the valve, allowing the chemical to be forced out.

Temperature Range: 40° F (4° C) to 120° F (49° C)

Construction: Stainless steel cylinder with protective nozzle tip orifice seal and non-metallic nozzle tip finger guard. Industry standard horn and nozzle design. Name plate shows only the class "K" symbol.

All units meet the current requirements established by the National Fire Protection Association (NFPA) for NFPA10 "Standard for Portable Fire Extinguishers", and any other applicable NFPA standards. Tested and listed by UL to meet construction and performance standards for this type of extinguisher, and can be used where required by local codes such as OSHA.

Qty.	Model	Type	Nominal Capacity	Shipping Weight	Cylinder Dia. In Inches	Overall Height In Inches	Overall Width In Inches	Shipping Vol	UL Rating 	Optional Mounting Bracket	USCG Approved
	Saturn 15	Class K Wet Chemical	1.8 gal	22.5 lbs	7	19-1/4	9	.9 cu.ft.	FK15A: 2-A-K FK15C: 1-A-K	MB810C or MB810A	--
	Saturn 25		2.5 gal	33.5 lbs.	7	24-1/2	9	1.1 cu.ft.	FK25A: 2-A-K FK25C: 1-A-K	MB810C or MB810A	--

J Hook wall bracket standard - Mounting bracket available at extra charge.

Note: NFPA regulations also require extinguishers to be inspected when initially placed in service and all local fire code and tagging requirements must be adhered to. All fire extinguisher sizes are nominal. Contact Customer Service for more information about ordering tagged extinguishers in your area.



Distributor:		Project:	
Contractor:		Approved By:	
Date:		Architect:	
Scale: N/A	Pages: 1 of 1	Item #:	

© 2019 Activar Construction Products Group, Inc.

THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF ACTIVAR CONSTRUCTION PRODUCTS GROUP, INC. ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE WRITTEN PERMISSION OF ACTIVAR CONSTRUCTION PRODUCTS GROUP, INC. IS PROHIBITED.

REV B - AUG 2019



FOR MORE INFORMATION CALL 1-888-926-1365

Superior Specialty Supply • 9 Council Drive • PO Box 417 • Woodsboro, MD 21798 • www.sssupply.com